

WELL CONSTRUCTOR'S REPORT

Well-6

FEB 26 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1 COUNTY Ozaukee		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City Cedarburg		NAME	
2 LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) 10607 Mill Rd. ? S45E2710N-21E					
3. OWNER AT TIME OF DRILLING Freeman Builder's, Inc.					
4. OWNER'S COMPLETE MAIL ADDRESS R 2 Williams Dr. Cedarburg, Wis.					
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED/INDEPENDENT
		12		32	12/
					WASTE WATER DRAIN C.I.
					40
CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN
38	100		-100-	110	
TILE					SILO
					ABANDONED WELL
					SINK HOLE
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)					

6. Well is intended to supply water for:

House

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	28	6	28	161	Stoney Clay	Surface	28
						Gravel	28	42
8. CASING, LINER, CURBING, AND SCREEN						Hardpan		
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)		Limestone	42	52
6	19.45# new bl steel		Surface	52			52	161
	T&C well cas.							
9. GROUT OR OTHER SEALING MATERIAL								
Kind			From (ft.)	To (ft.)				
Clay slurry			Surface	28				
11. MISCELLANEOUS DATA						Well construction completed on 2/22/71 19		
Yield test:		10	Hrs. at	15	GPM	Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Depth from surface to normal water level		25	ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth to water level when pumping		40	ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to		Madison		laboratory on:		2/22/71		19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Robert Demuth</i>	COMPLETE MAIL ADDRESS 631 South Wash. Ave. Cedarburg, Wis.
Registered Well Driller	

Please do not write in space below

GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS



REV 11 68